



Warrington Road, Risley, Warrington, Cheshire  
WA3 6BZ  
Tel: 01925 895588 Fax: 01925 895551

**CERTIFICATE OF TEST FOR EASE OF DECONTAMINATION**  
**BS 4247 PART 1 TEST A**

**Test Certificate Number:** 2000027.2  
**Test Completion Date :** 23 February 2000  
**Manufacturer or Supplier:** Trespa UK Limited  
Grosvenor House, Hollinswood Road  
Central Park  
Telford,  
TF2 9TW

**Product Description:** Trespa Athlon  
  
Colour : Silver grey  
Substrate Description: Self supporting  
Substrate Preparation : None  
Treatment of sample prior to test : None

**Test Results:**  
Decontamination Factor (Geometric Mean) : 680  
Deviation Parameter : 1.56  
Ease of Decontamination Classification : Good

Laboratory Remarks:  
No increase in counter background was observed when a sample coupon was counted prior to contamination.

**Test Laboratory:**

NIRAS, NNC Limited, Warrington Road, Risley, Warrington, WA3 6BZ, England  
Tel: 01925 895588 Fax: 01925 895551

Certificate Prepared by: (sign) *B. Frith* (print) B. FRITH  
Approved for issue by : (sign) *A. Frith* (print) A. FRITH

